



1600 South Second Street  
 Mount Vernon, WA 98273-5202  
 ph 360.428.1617  
 fax 360.428.1620  
 www.nwcleanair.org

## STAGE 1 TANKS SELF INSPECTION LOG SHEET

### INSPECT BETWEEN FUEL DELIVERIES

↓ MONTH		DUST CAP	ADAPTORS	SPILL BUCKET	FILL TUBE GASKETS	POPPET VALVES	INITIALS
DAY	↓ TIME:	Tight & gasket OK	Tight	<1" liquid; no vapor from drain valve	In place & in good condition (dual point & coaxial)	Seated properly (dual point only)	
1	am pm						
2	am pm						
3	am pm						
4	am pm						
5	am pm						
6	am pm						
7	am pm						
8	am pm						
9	am pm						
10	am pm						
11	am pm						
12	am pm						
13	am pm						
14	am pm						
15	am pm						
16	am pm						
17	am pm						
18	am pm						
19	am pm						
20	am pm						
21	am pm						
22	am pm						
23	am pm						
24	am pm						
25	am pm						
26	am pm						
27	am pm						
28	am pm						
29	am pm						
30	am pm						
31	am pm						

**OK** = okay **R** = replace **RR** = repaired (follow your approved procedures for making repairs)